

Monthly Requirements

R7-2005-0083

Coachella SD WWTP

Narrative:

- M-001C
 - E.coli: Wastewater effluent discharged shall not have an Escherichia coli (E. coli) concentration in excess of a log mean of Most Probable Number (MPN) of 126 MPN per 100 milliliters (based on a minimum of not less than five samples during the calendar month. (Final requirement effective null - null)[All year]

Pre-calculated:

- N/A

Data Dump:

[Coachella SD WWTP](#)

[R7-2005-0083](#)

M-001A

Flow	1 / Day	MGD
Total Suspended Solids (TSS)	2 / Week	mg/L
Biochemical Oxygen Demand (BOD) (5-day @ 20 Deg. C)	1 / Week	mg/L
BOD5 @ 20 Deg. C, Percent Removal	1 / Month	%
Total Suspended Solids (TSS), Percent Removal	1 / Month	%

M-001B

Flow	1 / Day	MGD
Total Suspended Solids (TSS)	2 / Week	mg/L
Biochemical Oxygen Demand (BOD) (5-day @ 20 Deg. C)	1 / Week	mg/L
BOD5 @ 20 Deg. C, Percent Removal	1 / Month	%
Total Suspended Solids (TSS), Percent Removal	1 / Month	%

M-001C

Temperature	1 / Day	Degrees F
Chlorine, Total Residual	5 / Week	mg/L
Chlorine, Total Residual	5 / Week	lb/day
pH	5 / Week	SU
E.coli	2 / Week	MPN/100 mL
Total Suspended Solids (TSS)	2 / Week	lb/day
Total Suspended Solids (TSS)	2 / Week	mg/L
Biochemical Oxygen Demand (BOD) (5-day @ 20 Deg. C)	1 / Week	mg/L
Biochemical Oxygen Demand (BOD) (5-day @ 20 Deg. C)	1 / Week	lb/day
Ammonia, Total (as N)	2 / Month	mg/L
Nitrogen, Total (as N)	1 / Month	mg/L
Phosphate, Total (as P)	1 / Month	mg/L

Orthophosphate, Total (as P)	1 / Month	mg/L
Total Dissolved Solids (TDS)	1 / Month	mg/L
Total Dissolved Solids (TDS)	1 / Month	lb/day
Copper, Total Recoverable	1 / Month	lb/day
Copper, Total Recoverable	1 / Month	ug/L
Bis (2-Ethylhexyl) Phthalate	1 / Month	lb/day
Bis (2-Ethylhexyl) Phthalate	1 / Month	ug/L
Nitrate, Total (as N)	1 / Month	mg/L
Nitrite, Total (as N)	1 / Month	mg/L

M-INF

Carbonaceous Biochemical Oxygen Demand (CBOD) (5-day @ 20 Deg. C)	1 / Week	mg/L
Total Suspended Solids (TSS)	1 / Week	mg/L

R-001D

Temperature	1 / Month	Degrees F
Chlorine, Total Residual	1 / Month	mg/L
Dissolved Oxygen	1 / Month	mg/L
Nitrate, Total (as N)	1 / Month	mg/L
Ammonia, Total (as N)	1 / Month	mg/L
Nitrogen, Total (as N)	1 / Month	mg/L
Phosphate, Total (as P)	1 / Month	mg/L
pH	1 / Month	SU
Hardness, Total (as CaCO3)	1 / Month	mg/L

R-001U

Temperature	1 / Month	Degrees F
Chlorine, Total Residual	1 / Month	mg/L
Dissolved Oxygen	1 / Month	mg/L
Nitrate, Total (as N)	1 / Month	mg/L
Ammonia, Total (as N)	1 / Month	mg/L
Nitrogen, Total (as N)	1 / Month	mg/L
Phosphate, Total (as P)	1 / Month	mg/L
pH	1 / Month	SU
Hardness, Total (as CaCO3)	1 / Month	mg/L